



NOTES:

- 1 - A MINIMUM OF 1 CLEANOUT SHALL BE PROVIDED 1-3 FEET OUTSIDE THE BUILDING FOOTINGS AND FOUNDATION. ON NEW CONSTRUCTION, CONNECTION OF ABS/SCHEDULE 40 PVC TO SDR-35 SHALL REQUIRE A GLUED FITTING USING ABS TO PVC TRANSITION CEMENT.
- 2 - CLEANOUTS SHALL BE SPACED AT INTERVALS NOT TO EXCEED 100 FEET.
- 3 - AN ADDITIONAL CLEANOUT SHALL BE PROVIDED FOR EACH AGGREGATE CHANGE OF DIRECTION EXCEEDING 135 DEGREES.
- 4 - EACH CLEANOUT SHALL BE INSTALLED ABOVE THE FLOW LINE OF THE PIPE USING A "WYE" FITTING SO THAT IT OPENS TO ALLOW CLEANING IN THE DIRECTION OF FLOW. A MINIMUM OF 1 FOOT OF PIPE IS REQUIRED BETWEEN BENDS.
- 5 - THE DISTRICT MAY REQUIRE CLEANOUTS AT OTHER LOCATIONS AND CONFIGURATIONS.
- 6 - THE UPPER END OF EACH CLEANOUT SHALL HAVE A SCREWED BRASS OR IRON CAP AND SHALL TERMINATE AT FINISH GRADE AFTER FINAL LANDSCAPING. IN PAVED AREAS, A TRAFFIC-RATED BOX AND CAST IRON LID MUST BE SET OVER THE SCREWED BRASS OR IRON CAP (SEE DETAIL SHEET 104-2).
- 7 - ADDITION OF A CLEANOUT ON AN EXISTING VITRIFIED CLAY OR CONCRETE LATERAL REQUIRES USE OF A SHEAR BAND COUPLER FITTING. THE FITTING SHALL BE SHADED IN SALT FROM THE SPRINGLINE UP TO THE TOP OF THE FITTING.

SCALE: NONE

ORIGINAL	
07/02/2020	LBH
REVISIONS	
07/22/2020	LBH

SOUTH DAVIS SEWER DISTRICT

**BUILDING SEWER
CLEANOUT DETAIL**



SHEET:

104-1